

Backflow Preventer Test Report

CRD Use Only	Facility ID No F-10422	Install ID No I-88131
---------------------	---------------------------	--------------------------

Designated Facility Contact Person Info (Please correct or add missing information)

Contact Person Name Dana Whitfield	Contact Person Title Property Manager	Contact Person Organization Harbourview Strata VIS 2210
Contact Person Mailing Address (Unit no, Street no, Street Name, City, Prov. Postal Code) #301, 1010 Wharf St, Victoria, BC V8W 1T4		
Contact Person Email Address dana@harbourviewstrata.example	Contact Phone No 250-555-0142	Contact Fax No
Contact Cell No (other)		

Facility Info (Please correct or add missing information)

Facility Name (Common name of building/structure of installed device) Harbourview Towers	Facility Type (See list on web site below) Multi-Residential	
Facility Unit no	Facility Address (Street no, Street Name or Park Name) 1010 Wharf Street	Permit No.
Facility Municipality Victoria	Name of Owner or Organization Harbourview Strata VIS 2210	Facility Hazard Level Moderate

BFP Info (BFP Tester - Please correct or add missing information)

BFP Make Watts	BFP Model No 009M2QT	BFP Serial No W123456	BFP Size (in) 2	BFP Type RPBA	Install Date (dd-mmm-yyyy) 14-May-2019
Location of BFP (Describe exact location within the facility where the BFP is situated) Mechanical room P1, north wall, 1.2 m AFF					BFP Orientation (H or V) H
Process Hazard Type (See list on website below) Domestic (multi-residential)					Line Pressure (psi) 68
Protection Type (1.Premises Isolation, 2.In-Premises, 3.Dedicated Fire Line, 4. Please Specify) 1. Premises Isolation					BFP Hazard Level Moderate

Initial BFP Test Results (BFP Tester - Record test results BEFORE repairs have been made)

BFP Type	☒ RPBA ☐ RPDA ☐ DCVA ☐ DCDA ☐ SVBA ☐ PVBA ☐ AIR GAP				
RPBA / RPDA	Check Valve # 1 RP pressure drop (A)	Check Valve # 2	Relief Valve (≥ 2 psid) Opened at (B)	Buffer (≥ 3 psid) A – B	Drain Air Gap Meets Code
Initial	6.2 psid ☒ Closed Tight ☐ Leaked	☒ Closed Tight ☐ Leaked	2.6 psid ☒ Passed ☐ Failed	3.6 psid ☒ Passed ☐ Failed	☒ Yes ☐ No
Result	PASSED				

Certified BFP Tester Info (BFP Tester - Please fill out this section and sign below)

Tester's Name (Please print) Ethan Kerr	Tester's BCWWA Cert. No BFT-000000	Company Name Example Backflow Ltd	Tester's Phone No 250-555-0199
Test Gauge Make Watts	Test Gauge Model No TK-9A	Test Gauge Serial No G-44120	Calibration Date (dd-mmm-yyyy) 04-Mar-2026 Calibrated By Mid-Island Calibration

Tester's Certification: I certify that I have tested the above assembly and that it meets the performance requirements outlined in the current edition of the BC Building Code and Canadian Standards Association - CAN/CSA B64.10

Tester's Signature	Date Test Completed (dd-mmm-yyyy) 02-Oct-2026	Owner's or Representative Signature
--------------------	--	-------------------------------------

E. Kerr

Mail or email **COMPLETED form to:** CRD Cross Connection Control · Email: ccc@crd.bc.ca · PO Box 1000, 625 Figgard Street, Victoria, BC V8W 2S6 · Tel: 250.474.9506 · Website: www.crd.ca/crossconnection **Copy to:** Municipality · Customer · Tester Prepared with BackflowFiled Updated July 2025