

Backflow deadline register — Example Property Management (SAMPLE)

As of 26-Sep-2026. One row per building: the water authority, the rule that sets its clock and whose words it is, the dates, the tester and whether the authority has the report. A building whose authority sets no deadline we could verify says so instead of showing a date. Every building, name and tester on this page is fictional; the rules are real and cited.

Building	Authority and rule	Notice	Tested	Report due	Tester	Report
Harbour View (SAMPLE) 100 Sample St, Victoria	Capital Regional District Within 35 days of the notice to test — Bylaw, Cross Connection Control Bylaw No. 3516, s.7.2	10-Sep-2026	22-Sep-2026	15-Oct-2026 19 days left	Tester A	Received
Oak Court (SAMPLE) 200 Sample Ave, Oak Bay	Capital Regional District Within 35 days of the notice to test — Bylaw, Cross Connection Control Bylaw No. 3516, s.7.2	15-Aug-2026	not yet	19-Sep-2026 7 days past	to assign	Not yet
Kingsway Tower (SAMPLE) 300 Sample Way, Burnaby	City of Burnaby Within 10 days of the test, as the City's test report form instructs — The authority's own test report form	—	20-Sep-2026	30-Sep-2026 4 days left	Tester B	Not yet
Cambie Lofts (SAMPLE) 400 Sample St, Vancouver	City of Vancouver Within 15 days of the test — Bylaw, Water Works By-law No. 4848, s.4.11(c)	—	18-Sep-2026	03-Oct-2026 7 days left	Tester B	Not yet
Departure Bay Place (SAMPLE) 500 Sample Rd, Nanaimo	City of Nanaimo No annual reporting deadline in Cross Connection Control Bylaw 2018 No. 7249, s.8.1–8.3; a test at least once every twelve months (s.8.2)	—	05-Sep-2026	No date the bylaw sets no annual report deadline	Tester C	Received
Fraser Commons (SAMPLE) 600 Sample Hwy, Abbotsford	City of Abbotsford Within 30 days of the test — Bylaw, Waterworks Regulation Bylaw 2665-2017, s.29(5)	—	01-Sep-2026	01-Oct-2026 5 days left	Tester A	Not yet

The date on each authority's own notice overrides this register. Rules are read from each authority's own bylaw, form or page; the directory at backflowfiled.com/jurisdictions links every one.